



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2019010307180395

纸 号: 2283585

型号的解释:

BBE M 3 - 80 □ / □ □

(1) (2) (3) (4) (5) (6) (7)

(1) 企业代号

(2) 塑料外壳式断路器

(3) 设计代号

(4) 壳架等级额定电流

(5) 分断能力级别: L、M

(6) 极数: "3" 表示三极(有 L、M 型), "4" 表示四极(仅 M 型)

(7) 脱扣器方式及附件代号(见表 1)

表 1 脱扣器方式及附件代号

附件名称	不带附件	分断脱扣器	一极辅助触头	分断脱扣器+辅助触头
过流脱扣器方式	代号			
复式脱扣器	300	310	320	340
电磁脱扣器	200	210	220	240

注: 此附录与证书同时使用时有效。



主 任: 陆楠



中国质量认证中心



中国国家强制性产品认证证书

证书编号: 2019010307180395

委托人名称、地址

浙江北华电气有限公司
浙江省温州市乐清市乐清经济开发区纬五路187号(浙江迈点电子股份有限公司内)

生产者(制造商)名称、地址

浙江北华电气有限公司
浙江省温州市乐清市乐清经济开发区纬五路187号(浙江迈点电子股份有限公司内)

生产企业名称、地址

浙江北华电气有限公司
浙江省温州市乐清市乐清经济开发区纬五路187号(浙江迈点电子股份有限公司内六楼)

产品名称和系列、规格、型号

塑料外壳式断路器

BHEM3-80L3、BHEM3-80M3、BHEM3-80M4; U: 800V; Uimp: 8kV; Ue: AC400V; In: 10A、15A、20A、25A、32A、40A、50A、63A、80A; 过电流脱扣器型式: 热磁式、单磁式; 使用类别: A; BHEM3-80L3: Ics=25kA, Icu=35kA; BHEM3-80M3、BHEM3-80M4: Ics=35kA, Icu=50kA; 辅助触头: 1NO1NC, 0h3A; AC-15; In: 0.3A, Ue: AC400V, DC-13; In: 0.15A, Ue: DC 220V, 极数: 3P (L、M) (3个保护极, 适用于隔离用)、4P (M) (3个保护极, N极可开闭, 适用于隔离用); 适用频率: 50/60Hz; 型号解释见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2019年05月07日 有效期至: 2024年05月07日
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307180395

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd

No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.C(In the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd

No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.C(In the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd

No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.C(In the JD Longwayflex Co., Ltd Floor 6)

PRODUCT NAME, MODEL AND SPECIFICATION

Moulded-Case Circuit-Breaker

BH-EM3-80L/3, BH-EM3-80M/3, BH-EM3-80M/4, U_i: 800V; U_{imp}: 8kV; U_e: AC400V ; I_n: 15A, 16A, 20A, 25A, 32A, 40A, 50A, 63A, 80A; Over-current Release: Thermal Magnetic, Single magnetic type; Utilization Category: A; BH-EM3-80L/3: I_{cu}=25kA, I_{cs}=35kA; BH-EM3-80M/3, BH-EM3-80M/4: I_{cu}=35kA, I_{cs}=50kA; Attached Auxiliary Contacts: 1NO/1NC, I_{th}3A; AC-15; I_e: 0.3A, U_e: AC400V, DC-13; I_e: 0.15A, U_e: DC 220V, Poles: 3P (L, M) (With three protective poles, Suitable for insulation) ; 4P (M) (With three protective poles, Switched neutral pole, Suitable for insulation) ; Frequency of operating cycles: 50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.07,2019

Valid until: May.07,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2019010307180396

版本号: 2283586

参数:

Ui: 1000V; Uimp: 8kV; Ue: AC400V (C, L, M, H),
 AC500V (仅 M, H), AC690V (仅 M, H); Im: 10A, 16A, 20A, 25A,
 32A, 40A, 50A, 63A, 80A, 100A, 125A; 过电流脱扣器型式: 热磁式,
 半磁式; 使用类别: A; AC400V: BHEM3-125C; Ics=18kA, Icu=25kA;
 BHEM3-125L; Ics=25kA, Icu=35kA; BHEM3-125M; Ics=35kA, Icu=50kA;
 BHEM3-125H; Ics=50kA, Icu=85kA; AC500V: BHEM3-125M; Ics=30kA,
 Icu=40kA; BHEM3-125H; Ics=35kA, Icu=50kA; AC690V: BHEM3-125M;
 Ics=8kA, Icu=10kA; BHEM3-125H; Ics=10kA, Icu=20kA; 辅助触头:
 1N01NC, Ith: 3A; AC-15; Ie: 0.3A, Ue: AC400V, DC-13; Ie: 0.15A,
 Ue: DC 220V, 适用频率: 50/60Hz; 极数: 2P, 3P (均为保护极, 适用于
 隔离用), 4P (三个保护极, N 极可开闭, 适用于隔离用)

型号的解释:

BHE M 3 - 125 □ / □ □

(1) (2) (3) (4) (5) (6) (7)

- (1) 企业代号
- (2) 塑料外壳式断路器
- (3) 设计代号
- (4) 壳架等级额定电流
- (5) 分断能力级别: C, L, M, H
- (6) "2" 表示二极, "3" 表示三极, "4" 表示四极
- (7) 脱扣器方式及附件代号 (见表 1)

注: 此附录与证书同时使用时有效。



主任:

陆楠



中国质量认证中心



中国国家强制性产品认证证书

证书编号: 2019010307180396

委托人名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江迈点电子股份有限公司内)

生产者(制造商)名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江迈点电子股份有限公司内)

生产企业名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江迈点电子股份有限公司内六楼)

产品名称和系列、规格、型号

塑料外壳式断路器

BHEM3-125; 参数及型号解释详见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2019年05月07日 有效期至: 2024年05月07日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307180396

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(In the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(In the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(In the JD Longwayflex Co., Ltd Floor 6)

PRODUCT NAME, MODEL AND SPECIFICATION

Moulded-Case Circuit-Breaker
BHEM3-125

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.07,2019

Valid until: May.07,2024

The validity of the certificate is subject to positive result of the regular follow up
inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2019010307180396

纸 号: 2283586

表 1 脱扣器方式及附件代号

附件名称	不带附件	分励脱扣器	一经辅助触头	分励脱扣器+辅助触头
过流脱扣器方 式	代号			
复式脱扣器	300	310	320	340
电磁脱扣器	200	210	220	240

注: 此附录与证书同时使用时有效。



主 任: 陆 楠



中国质量认证中心



中国国家强制性产品认证证书

证书编号: 2019010307180880

委托人名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号 (浙江进点电子股份有限公司内)

生产者 (制造商) 名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号 (浙江进点电子股份有限公司内)

生产企业名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号 (浙江进点电子股份有限公司内六楼)

产品名称和系列、规格、型号

塑料外壳式断路器

BHEM3-250; 参数及型号解释详见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2019 年 05 月 07 日 有效期至: 2024 年 05 月 07 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307180880

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(In the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(In the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(In the JD Longwayflex Co., Ltd Floor 6)

PRODUCT NAME, MODEL AND SPECIFICATION

Moulded-Case Circuit-Breaker
BHEM3-250; See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: May.07,2019

Valid until: May.07,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2019010307180880

纸 号: 2283588

参数:

Ui: 1000V; Uimp: 8kV; Ue: AC400V (C, L, M, H),
 AC500V (仅 M, H), AC690V (仅 M, H); In: 100A, 125A, 140A, 160A,
 180A, 200A, 225A, 250A; 过电流脱扣器型式: 热磁式、单磁式; 使用类
 别: A; AC400V: BHEM3-250C; Ics=18kA, Icu=25kA; BHEM3-250L;
 Ics=25kA, Icu=35kA; BHEM3-250M; Ics=35kA, Icu=50kA; BHEM3-250H;
 Ics=50kA, Icu=85kA; AC500V: BHEM3-250M; Ics=30kA, Icu=40kA;
 BHEM3-250H; Ics=35kA, Icu=50kA; AC690V: BHEM3-250M; Ics=8kA,
 Icu=10kA; BHEM3-250H; Ics=15kA, Icu=20kA; 辅助触头: 1NO1NC, 1th: 3A;
 AC-15; Ie: 0.3A, Ue: AC400V, DC-13; Ie: 0.15A, Ue: DC 220V, 适用
 频率: 50/60Hz; 极数: 2P, 3P (均为保护极, 适用于隔离用), 4P (三个保
 护极, N 极可开闭, 适用于隔离用)

型号的解释:

BHE M 3 - 250 □ / □ □

(1) (2) (3) (4) (5) (6) (7)

- (1) 企业代号
- (2) 塑料外壳式断路器
- (3) 设计代号
- (4) 壳架等级额定电流
- (5) 分断能力级别: C, L, M, H
- (6) "2" 表示二极, "3" 表示三极, "4" 表示四极
- (7) 脱扣器方式及附件代号 (见表 1)

注: 此附录与证书同时使用时效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2019010307180880

纸 号: 2283588

表 1 脱扣器方式及附件代号

附件名称	不带附件	分励脱扣器	一扭辅助触头	分励脱扣器+辅助触头
过流脱扣器方式	代号			
复式脱扣器	300	310	320	340
电磁脱扣器	200	210	220	240

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2019010307180678

版本号: 2283587

参数:

Ui:1000V; Uimp:12kV; Ue: AC400V/500V/690V; In:
 225A、250A、315A、350A、400A; 过电流脱扣器型式: 热磁式、单磁式;
 使用类别: A; AC400V: BHEM3-400L: Ics=35kA, Icu=50kA; BHEM3-400M:
 Ics=50kA, Icu=70kA; BHEM3-400H: Ics=65kA, Icu=85kA; AC500V:
 BHEM3-400L: Ics=18kA, Icu=25kA; BHEM3-400M: Ics=25kA, Icu=35kA;
 BHEM3-400H: Ics=35kA, Icu=50kA; AC690V: BHEM3-400L: Ics=8kA,
 Icu=10kA; BHEM3-400M: Ics=15kA, Icu=20kA; BHEM3-400H: Ics=15kA,
 Icu=20kA; 辅助触头: 2NO2NC, Ith:3A; AC-15: Ie: 0.4A, Ue: AC400V,
 DC-13: Ie: 0.15A, Ue: DC 220V, 极数: 3P (3 个保护极, 适用于隔离用)、
 4P (3 个保护极, N 极可开闭, 适用于隔离用); 适用频率: 50/60Hz

型号的解释:

BHE M 3 - 400 □ / □ □

(1) (2) (3) (4) (5) (6) (7)

- (1) 企业代号
- (2) 塑料外壳式断路器
- (3) 设计代号
- (4) 壳架等级额定电流
- (5) 分断能力级别: L、M、H
- (6) “3”表示三极,“4”表示四极
- (7) 脱扣器方式及附件代号(见表1)

注: 此附录与证书同时使用时效。



主任:

陆楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2019010307180878

纸 号: 2283587

表 1 脱扣器方式及附件代号

附件名称	不带附件	分励脱扣器	二极辅助触头	分励脱扣器+辅助触头
过流脱扣器方式	代号			
复式脱扣器	300	310	320	340
电磁脱扣器	200	210	220	240

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

证书编号: 2019010307180878

委托人名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号 (浙江过点电子股份有限公司内)

生产者 (制造商) 名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号 (浙江过点电子股份有限公司内)

生产企业名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号 (浙江过点电子股份有限公司内六楼)

产品名称和系列、规格、型号

塑料外壳式断路器

BHEM3-400: 参数及型号解释详见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2019 年 05 月 07 日 有效期至: 2024 年 05 月 07 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307180878

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(In the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(In the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(In the JD Longwayflex Co., Ltd Floor 6)

PRODUCT NAME, MODEL AND SPECIFICATION

Moulded-Case Circuit-Breaker
BHEM3-400; See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO.CNCA-C03-02-2014).

Valid from: May.07,2019

Valid until: May.07,2024

The validity of the certificate is subject to positive result of the regular follow up
inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2019010307180881

纸 号: 2283589

参数:

Ui:1000V; Uimp:12kV; Ue: AC400V/500V/690V ; In:

400A、500A、630A; 过电流脱扣器型式: 热磁式、电磁式; 使用类别: AC400V:

BHEM3-630L: Ics=35kA, Icu=50kA; BHEM3-630M: Ics=50kA, Icu=70kA;

BHEM3-630H: Ics=65kA, Icu=85kA; AC500V: BHEM3-630L: Ics=18kA,

Icu=25kA; BHEM3-630M: Ics=25kA, Icu=35kA; BHEM3-630H: Ics=35kA,

Icu=50kA; AC690V: BHEM3-630L: Ics=8kA, Icu=10kA; BHEM3-630M:

Ics=15kA, Icu=20kA; BHEM3-630H: Ics=15kA, Icu=20kA; 辅助触头:

2NO2NC, Ith:3A; AC-15: Ie: 0.4A, Ue: AC400V, DC-13: Ie: 0.15A,

Ue: DC 220V, 极数: 3P (3 个保护极, 适用于隔离用)、4P (3 个保护极,

N 极可开闭, 适用于隔离用) 适用频率: 50/60Hz

型号的解释:

BHE M 3 — 630 □ / □ □

(1) (2) (3) (4) (5) (6) (7)

- (1) 企业代号
- (2) 塑料外壳式断路器
- (3) 设计代号
- (4) 壳架等级额定电流
- (5) 分断能力级别: L、M、H
- (6) “3”表示三板, “4”表示四板
- (7) 脱扣器方式及附件代号 (见表 1)

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2019010307180881

纸 号: 2283589

表 1 脱扣器方式及附件代号

附件名称	不带附件	分励脱扣器	二极辅助触头	合励脱扣器+辅助触头
过流脱扣器方 式	代号			
复式脱扣器	300	310	320	340
电磁脱扣器	200	210	220	240

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

证书编号: 2019010307180881

委托人名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江近点电子股份有限公司内)

生产者(制造商)名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江近点电子股份有限公司内)

生产企业名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江近点电子股份有限公司内六楼)

产品名称和系列、规格、型号

塑料外壳式断路器

BHEM3-630; 参数及型号解释详见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2019年05月07日 有效期至: 2024年05月07日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307180881

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(In the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(In the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(In the JD Longwayflex Co., Ltd Floor 6)

PRODUCT NAME, MODEL AND SPECIFICATION

Moulded-Case Circuit-Breaker
BHEM3-630; See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02-2014).

Valid from: May.07,2019

Valid until: May.07,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2019010307180882

纸 号: 2283590

型号的解释:

BHE M 3 - 800 □ / □ □

(1) (2) (3) (4) (5) (6) (7)

- (1) 企业代号
- (2) 塑料外壳式断路器
- (3) 设计代号
- (4) 壳架等级额定电流
- (5) 分断能力级别: M、H
- (6) “3”表示三极,“4”表示四极
- (7) 脱扣器方式及附件代号(见表 1)

表 1 脱扣器方式及附件代号

附件名称	不带附件	分励脱扣器	二极辅助触头	分励脱扣器+辅助触头
过流脱扣器方式	代号			
复式脱扣器	300	310	320	340
电涌脱扣器	200	210	220	240

注: 此附录与证书同时使用时效。



主 任: 陆 楠



中国质量认证中心



中国国家强制性产品认证证书

证书编号: 2019010307180882

委托人名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江近点电子股份有限公司内)

生产者(制造商)名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江近点电子股份有限公司内)

生产企业名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路187号(浙江近点电子股份有限公司内六楼)

产品名称和系列、规格、型号

塑料外壳式断路器

BHEM3-800: U_i: 1000V; U_{imp}: 12kV; U_e: AC400V/690V; I_n: 500A, 630A, 700A, 800A; 过电流脱扣器型式: 热磁式、单磁式; 使用类别: A; AC400V: BHEM3-800M; I_{cs}=50kA, I_{cu}=70kA; BHEM3-800H; I_{cs}=65kA, I_{cu}=85kA; AC690V: I_{cs}=15kA, I_{cu}=20kA; 辅助触头: 2NO2NC, 2th3A; AC-15: I_e: 0.4A, U_e: AC400V, DC-13: I_e: 0.15A, U_e: DC 220V, 极数: 3P (3个保护极, 适用于隔离用), 4P (3个保护极, N极可断开, 适用于隔离用) 适用频率: 50/60Hz; 型号解释见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求, 特发此证。

发证日期: 2019年05月07日 有效期至: 2024年05月07日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307180882

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd

No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.C(In the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd

No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.C(In the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd

No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.C(In the JD Longwayflex Co., Ltd Floor 6)

PRODUCT NAME, MODEL AND SPECIFICATION

Moulded-Case Circuit-Breaker

BHEM3-800, U_i: 1000V, U_{imp}: 12kV, U_e: AC400V/800V, I_n: 500A, 630A, 700A, 800A, Over-current Release: Thermal Magnetic, Single magnetic type, Utilization Category : A, AC400V, BHEM3-800M, I_{cs}=50kA, I_{cu}=70kA, BHEM3-800H, I_{cs}=65kA, I_{cu}=85kA, AC800V, I_{cs}=15kA, I_{cu}=20kA, Attached Auxiliary Contacts: 2NC2NC, I_{th}3A, AC-15, I_e: 0.4A, U_e: AC400V, DC-13, I_e: 0.15A, U_e: DC 220V, Poles: 3P (With three protective poles, Suitable for insulation) , 4P (With three protective poles, Switched neutral pole, Suitable for insulation) Frequency of operating cycles: 50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02-2014).

Valid from: May.07,2019

Valid until: May.07,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE