



中国国家强制性产品认证证书

所 求

第 1 页 共 1 页

证书编号: 2019010307167631

纸 号: 2230475

型号的解释:

BHE M 3 E - □ □ / □ □

- (1) 企业代号
- (2) 塑料外壳式断路器
- (3) 设计代号
- (4) 电子式
- (5) 额定电流 (A): 800, 630
- (6) 分断能力级别: M, H
- (7) 极数: 3 代表 3 极, 4 代表 4 极
- (8) 脱扣器方式及附件代号 (见表 1)

表 1 脱扣器方式及附件代号

附件名称	不带附件	分励脱扣器	一组辅助触头	分励脱扣器+一组辅助触头
过流脱扣器方式			代号	
复式脱扣器	400	410	420	440

注: 此附录与证书同时使用时有效。



主 任: 李本初



中国质量认证中心



中国国家强制性产品认证证书

附录

第1页共2页

证书编号: 2019010307167331

纸号: 2230478

BHEM3E-125

Ui: 1000V;

Uimp: 8kV;

Uer: AC 400V/415V/690V;

In: 32A (16, 20, 25, 32A 可调), 63A (32, 35, 40, 45, 50, 55, 60, 63A 可调),
125A (63, 65, 70, 75, 80, 85, 90, 95, 100, 125A 可调);

过电流脱扣器型式: 电子式;

使用类别: A 类;

AC400/415V: BHEM3E-125L; Ics=18kA, Icu=35kA; BHEM3E-125M; Ics=35kA, Icu=50kA;
BHEM3E-125H; Ics=55kA, Icu=85kA;

AC690V: BHEM3E-125L; Ics=8kA, Icu=10kA; BHEM3E-125M/ BHEM3E-125H; Ics=10kA,
Icu=20kA;

Iew: 1.5kA/0.5s;

辅助触头: INOINC, Ith:3A; AC-15; Ie: 0.3A, Ue: AC400V, DC-13; Ie: 0.15A,
Ue: DC220V,

极数: 3P (三个保护极, 适用于隔离用), 4P (三个保护极, N 极可开闭, 适用于隔
离用);

频率适用于: 50/60Hz

注: 此附录与证书同时使用时有效。



主任:

陈楠



中国质量认证中心



中国国家强制性产品认证证书

附录

证书编号：2019010307167331

第2页共2页

纸号：2230478

型号解释：

BHE M 3 E - 125 □ / □ □
 (1) (2) (3) (4) (5) (6) (7) (8)

- (1) 企业代号
- (2) 塑料外壳式断路器
- (3) 设计代号
- (4) 电子式
- (5) 壳架等级额定电流
- (6) 分断能力级别：L、M、H
- (7) 极数：3代表3极，4代表4极
- (8) 现扣器方式及附件代号（见表1）

表1 现扣器方式及附件代号

附件名称	不带附件	分励脱扣器	一扭精助触头
过流脱扣器方式	代号		
复式脱扣器	400	410	420

注：此附录与证书同时使用时有效。



主任：李楠



中国质量认证中心



中国国家强制性产品认证证书

证书编号：2019010307167331

委托人名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号（浙江近点电子股份有限公司内）

生产者（制造商）名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号（浙江近点电子股份有限公司内）

生产企业名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号（浙江近点电子股份有限公司内六楼）

产品名称和系列、规格、型号

塑料外壳式断路器

BHEM3E-125, 具体参数和型号解释详见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，
特发此证。

发证日期：2019 年 03 月 27 日 有效期至：2024 年 03 月 27 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：陈楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307167331

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(in the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(in the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(in the JD Longwayflex Co., Ltd Floor 6)

PRODUCT NAME, MODEL AND SPECIFICATION

Moulded-Case Circuit-Breaker
BHEM3E-125;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Mar.27,2019

Valid until: Mar.27,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

卢梅

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录

第1页共2页

证书编号：2019010307167330

纸号：2230474

BHEM3E-250;

Ui: 1000V;

Uimp: 8kV;

Ue: AC 400V/415V/690V ;

Im: 250A(100A、125A、140A、160A、180A、200A、225A、250A 可调)；

过电流脱扣器型式：电子式；

使用类别：B₃

AC400/415V; BHEM3E-250L; Ics=18kA, Icu=35kA; BHEM3E-250M; Ics=35kA, Icu=50kA;
BHEM3E-250H; Ics=55kA, Icu=85kA;

AC690V; BHEM3E-250L; Ics=8kA, Icu=10kA; BHEM3E-250M/BHEM3E-250H; Ics=10kA,
Icu=20kA;

Icw=5kA/0.5s;

辅助触头：IN01NC, Ith:3A; AC-15; Ie: 0.3A, Ue: AC400V, DC-13; Ie: 0.15A,
Ue: DC 220V;

极数：3P（三个保护极，适用于隔离开用）、4P（三个保护极，N极可开闭，适用于隔
离用）；

频率适用于：50/60Hz

注：此附录与证书同时使用时有效。



主任：

陈楠



中国质量认证中心



中国国家强制性产品认证证书

附录

证书编号: 2019010307167330

第 2 页 共 2 页

纸号: 2230474

型号的解释:

BHE M 3 E - 250 □ / □ □
 (1) (2) (3) (4) (5) (6) (7) (8)

- (1) 企业代号
- (2) 塑料外壳式断路器
- (3) 设计代号
- (4) 电子式
- (5) 壳架等极额定电流
- (6) 分断能力级别: L、M、H
- (7) 极数: 3 代表 3 极, 4 代表 4 极
- (8) 脱扣器方式及附件代号 (见表 1)

表 1 脱扣器方式及附件代号

附件名称	不带附件	分励脱扣器	一组辅助触头
过流脱扣器方式	代号		
复式脱扣器	400	410	420

注: 此附录与证书同时使用时有效。



主任: 李楠



中国质量认证中心



中国国家强制性产品认证证书

证书编号：2019010307167330

委托人名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号（浙江近点电子股份有限公司内）

生产者（制造商）名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号（浙江近点电子股份有限公司内）

生产企业名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号（浙江近点电子股份有限公司内六楼）

产品名称和系列、规格、型号

塑料外壳式断路器

BHEM3E-250, 具体参数和型号解释详见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，
特发此证。

发证日期：2019 年 03 月 27 日 有效期至：2024 年 03 月 27 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任：陈楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307167330

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(in the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(in the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd
No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang
Province,P.R.C(in the JD Longwayflex Co., Ltd Floor 6)

PRODUCT NAME, MODEL AND SPECIFICATION

Moulded-Case Circuit-Breaker
BHEM3E-250;See the Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Mar.27,2019

Valid until: Mar.27,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

卢梅

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附录

第1页共1页

证书编号：2019010307167630

纸号：2230477

型号的解释：

BHE M 3 E - 400 □ / □ □
 (1) (2) (3) (4) (5) (6) (7) (8)

- (1) 企业代号
- (2) 塑料外壳式断路器
- (3) 设计代号
- (4) 电子式
- (5) 壳架等级额定电流
- (6) 分断能力级别：L、M、H
- (7) 极数：3代表3极，4代表4极
- (8) 脱扣器方式及附件代号（见表1）

表1 脱扣器方式及附件代号

附件名称	不带附件	分励脱扣器	一组辅助触头
过流脱扣器方式	代号		
复式脱扣器	400	410	420

注：此附录与证书同时使用时有效。



主任：陈书



中国质量认证中心



中国国家强制性产品认证证书

证书编号：2019010307167630

委托人名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号（浙江近点电子股份有限公司内）

生产者（制造商）名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号（浙江近点电子股份有限公司内）

生产企业名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号（浙江近点电子股份有限公司内六楼）

产品名称和系列、规格、型号

塑料外壳式断路器

BHEM3E-400；Ui: 1000V; Uimp: 12kV; Ue: AC 400V/415V/690V; In: 400A(200A, 225A, 250A, 280A, 315A, 350A, 400A 可调); 过电流保护器型式：电子式；使用类别：B；适用于隔离；AC400V/15V; BHEM3E-400L; Ics=350A, Icu=50kA; BHEM3E-400M; Ics=500A, Icu=65kA; BHEM3E-400H; Ics=650A, Icu=100kA; AC690V; BHEM3E-400L; Ics=80A, Icu=10kA ; BHEM3E-400MBHEM3E-400H : Ics=150A , Icu=20kA ; low5KA1s；触点形式：1NO1NC, B:3A ; AC-15; le: 0.4A, Ue: AC400V, DC-13; le: 0.15A, Ue: DC220V, 极数：3P（三个保护极，适用于家用）、4P（三个保护极，N 极可断开，适用于隔离用），频率范围：50/60Hz; 型号解释见附件

产品标准和技术要求

GB/T14048. 2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，特发此证。

发证日期：2019 年 03 月 27 日 有效期至：2024 年 03 月 27 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询。



主任：陈楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307167630

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd

No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.C(in
the JD Longwayflex Co.,Ltd)

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd

No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.C(in
the JD Longwayflex Co.,Ltd)

NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd

No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.C(in
the JD Longwayflex Co.,Ltd Floor 6)

PRODUCT NAME, MODEL AND SPECIFICATION

Moulded-Case Circuit-Breaker

BHEM3E-400: Ue: 1000V; Uimp: 12kV; Ue: AC 400V/415V/500V ; In: 400A/200A, 225A, 250A, 280A, 315A, 350A, 400A; II (IEC). Over-current Release: Electronic, Utilization Category: B; Suitable for I insulation; AC400/415V; BHEM3E-400L: Ics=350A, Icu=50kA; BHEM3E-400M: Ics=50kA, Icu=65kA; BH EM3E-400H: Ics=65kA, Icu=120kA; AC690V; BHEM3E-400L: Ics=50A, Icu=10kA ; BHEM3E-400MBHE M3E-400H : Ics=150A ; Icu=200A ; Icw=5kA/1s; Attached Auxiliary Contacts: 1NO/1NC, Ith=3A; AC-15; Ie: 0.4A, Ue: AC400V, DC-13; Ie: 0.15A, Ue: DC220V. Poles: 3P (With three protective poles, Suitable for insulation) , 4P (With three protective poles,Switched neutral pole, Suitable for insulation) . Frequency of operating cycles: 50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Mar.27,2019

Valid until: Mar.27,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

证书编号: 2019010307167631

委托人名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号（浙江近点电子股份有限公司内）

生产者（制造商）名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号（浙江近点电子股份有限公司内）

生产企业名称、地址

浙江北华电气有限公司

浙江省温州市乐清市乐清经济开发区纬五路 187 号（浙江近点电子股份有限公司内六楼）

产品名称和系列、规格、型号

塑料外壳式断路器

BHEM3E-800、BHEM3E-630 UI:1000V : Ue:AC400V/415V/690V; In: 630A/250A、280A、315A、350A、375A、400A、450A、500A、560A、630A 可调; 800A/15A、350A、400A、450A、500A、560A、630A、700A、780A、800A 可调); 额定电流脱扣器型式: 电子式; 使用类别: B; AC400/415V: BHEM3E-800M/BHEM3E-630M; Is=50kA, Icu=75kA; BHEM3E-800H/BHEM3E-630H; Is=65kA, Icu=100kA; AC690V: Is=20kA, Icu=30kA; low=10kA/1s; 热脱扣头: 1NO1NC, Rh:3A; AC-15; le: 0.4A, Ue: AC 400V, DC-13; le: 0.15A, Ue: DC220V, 极数: 3P (三个保护极, 适用于隔离用), 4P (三个保护极, N 极可共用, 适用于隔离用), 频率适用于: 50/60Hz; 型号解译见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2019 年 03 月 27 日 有效期至: 2024 年 03 月 27 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询。



主任: 陈楠



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2019010307167631

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Beihua Electrical Co., Ltd

No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.C(in the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Beihua Electrical Co., Ltd

No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.C(in the JD Longwayflex Co., Ltd)

NAME AND ADDRESS OF THE FACTORY

Zhejiang Beihua Electrical Co., Ltd

No.187,Wei 5th Road,Yueqing Economic Development Zone,Yueqing City,Zhejiang Province,P.R.C(in the JD Longwayflex Co., Ltd Floor 6)

PRODUCT NAME, MODEL AND SPECIFICATION

Moulded-Case Circuit-Breaker

BHEM3E-800 . BHEM3E-630 UI:1000V : Uimp:12kV : Ue:AC400V/415V/880V; In: 630A/250A, 280A, 315A, 350A, 375A, 400A, 450A, 500A, 560A, 630A; I_c(IR): 800A(315A, 350A, 400A, 450A, 500A, 560A, 630A, 700A, 760A, 800A; I_c(UR): Over-current Release Electronic, Utilization Category: B; AC400V/880V; BHEM3E-800M BHEM3E-630M; I_c=50kA, I_c=75kA, BHEM3E-800H BHEM3E-630H; I_c=65kA, I_c=100kA; AC880V; I_c=20kA, I_c=30kA; I_c=10kA/1s; Attached Auxiliary Contacts: 1NO1NC, I_b:3A; AC-15; I_b: 0.4A; Ue: AC 400V, DC-13; I_e: 0.15A, Ue: DC220V; Poles: 3P (With three protective poles, Suitable for insulation) , 4P (With three protective poles,Switched neutral pole, Suitable for insulation) . Frequency of operating cycles: 50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Mar.27,2019

Valid until: Mar.27,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

卢梅

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE